

2018-2019年农职院冬季取暖用电情况一览表

序号	学校	建筑面积 (m ²)	3月8日电表数	互感器变比倍数	耗电量 (度)	电费单价 (元/度)	电费总数 (元)	折合每平方米取暖费 (元/m ²)
1	行政楼	3187.6	2589.7	80	207176	0.5	103588	32.50
2	教学楼	13070	304	160	48640	0.5	24320	13.53
3			1907.2	160	305152	0.5	152576	
4	综合楼	5400	1698.3	160	271728	0.5	135864	25.16
5	图书馆	12430	73.1	120	8772	0.5	4386	12.60
6			1676.9	80	134152	0.5	67076	
7			1420.3	120	170436	0.5	85218	
8	园林楼	3460	1734	100	173400	0.5	86700	25.06
9	食堂	7380.5	1687	80	134960	0.5	67480	23.18
10			2072.5	100	207250	0.5	103625	
11	第一公寓	11145	1765.2	120	211824	0.5	105912	19.79
12			749.7	80	59976	0.5	29988	
13			1410.2	120	169224	0.5	84612	
14	第二公寓	3011	2089.7	80	167176	0.5	83588	27.76
15	第三公寓	5863	1328.8	160	212608	0.5	106304	18.13
16	第四公寓	7800	2025	120	243000	0.5	121500	25.01
17			1226	120	147120	0.5	73560	

18	第五公寓	9409.63	1447.3	160	231568	0.5	115784	23.11
19			2033.6	100	203360	0.5	101680	
20	第六公寓（培中）	4453	1568.5	160	250960	0.5	125480	28.18
21	第七公寓	6518.52	3736.8	80	298944	0.5	149472	46.19
22			3790.1	80	303208	0.5	151604	
23	实训（一）	7516	2207.2	80	176576	0.5	88288	21.10
24			1758	80	140640	0.5	70320	
25	实训（二）	10086	1256.8	120	150816	0.5	75408	17.09
26			1211.5	160	193840	0.5	96920	
27	牧医楼	2523.4	1427	80	114160	0.5	57080	22.62
28	活动中心	1250	811.8	60	48708	0.5	24354	19.48
		114503.65			4985374		2492687	21.8



0 4 2 0 kW·h

② 0 1 7 3 4 0 kW·h

② 0 1 6 8 7 0 kW·h

③ 0 2 0 7 2 0 kW·h

② 0 1 7 6 5 2 kW·h

② 0 0 7 4 9 7 kW·h

② 0 1 4 1 0 4 kW·h

② 0 2 0 8 9 7 kW·h

② 0 1 3 2 8 7 kW·h
PA 2011E392-33



